



OFFICE OF THE GUWAHATI MUNICIPAL CORPORATION  
HEALTH BRANCH: GUANHTOKIA: GUWAHATI

No-GHL/707/09/Pt-I/56

Dated- 23-06-2021

TO WHOM IT MAY CONCERN

*This is to acknowledge that required hygienicity and sanitary provision at SBOA Public School at Gorchuk, NH-37, Guwahati-781035, such as separate toiletry provision for boys and girls, provision of ablution taps with running water and drinking water facilities are adequate in nature. General cleanliness of the school premise is found satisfactory and up to the level of satisfaction.*

*M. S. Saha*  
23/6/2021  
Sr. Medical Officer  
Guwahati Municipal Corporation  
Guwahati



GOVT. OF ASSAM  
STATE PUBLIC HEALTH LABORATORY : ASSAM  
BAMMUNIMAIMAM, GUWAHATI-21

REPORT OF THE FOOD ANALYST

Laboratory Code No. : Chem. 354/2021  
Date of Receipt : 05-05-2021  
Sent by : SBOA Public School, Garchuk, Ghy-35  
Mr. David Barman, Principal,

Sl. No.	Parameter	Nature of method used	Result	Desirable limit
1	Appearance	FSSAI Manual	Clear	Clear
2	Odour	-do-	Unobjectionable	Unobjectionable
3	Taste	-do-	--	Agreeable
4	Turbidity, NTU	-do-	0	5(Max)
5	pH	-do-	6.8	6.5 to 8.5
6	Total hardness (as CaCO <sub>3</sub> ), mg/l	-do-	124.2	200(Max)
7	Iron (Fe), mg/l	-do-	0.02	0.30 (Max)
8	Chlorides (as Cl), mg/l	-do-	18	250 (Max)
9	Residual free Chlorine, mg/l	-do-	Nil	0.20 (Max)
10	Fluoride (as F), mg/l	-do-	0.54	1.0 (Max)
11	Dissolved Solids, mg/l	-do-	163	500 (Max)
12	Calcium (as Ca) mg/l	-do-	24.5	75 (Max)
13	Magnesium (as Mg), mg/l	-do-	15.3	30 (Max)
14	Manganese (as Mn), mg/l	-do-	Nil	0.10 (Max)
15	Sulphate (as SO <sub>4</sub> ), mg/l	-do-	107	200 (Max)
16	Nitrates (as NO <sub>3</sub> ), mg/l	-do-	Nil	45 (Max)
17	Phenolic Compounds (as C <sub>6</sub> H <sub>5</sub> OH)	-do-	Nil	0.001(Max)
18	Mineral Oil, mg/l	-do-	Nil	0.50 (Max)
19	Alkalinity as (CaCO <sub>3</sub> ), mg/l	-do-	132	200 (Max)

OPINION: THE SAMPLE IS CHEMICALLY SATISFACTORY WITH RESPECT TO THE TESTS CARRIED OUT.



(A. Gogoi)  
Food Analyst for the Govt. of Assam  
Bamunimaidam, Guwahati-21